

Guidance on Separation Distances Between Drinking Water Lines and Stormwater Facilities:

- | | |
|--|--------|
| 1) Rivers, creeks, canals, irrigation ditches,
including vegetated swale BMP #38,
and continuous roadside infiltration ditches
also called “borrow pits” | 10 ft. |
| 2) Curb and gutter (intermittent) | 10 ft. |
| 3) Detention or infiltration basins, including
a) BMP # 44 (infiltration basin) and
b) BMP # 48 (dry extended pond). | 10 ft. |
| 4) Subsurface Stormwater Infiltration trenches,
including BMP #43 and sand filters (BMP #40) | 25 ft. |
| 5) Continuously full retention ponds (lined)
a) BMP #45-wet pond; b) BMP #46-wet
b) extended pond and c) BMP #49-constructed
(lined) wetland. Leakage testing required. | 10 ft. |
| 6) Unlined, continuously wet ponds, such as
water amenities and unlined constructed
wetlands that receive storm water. | 25 ft. |